East Windsor Department of Public Works Sidewalk Replacement Main Street Warehouse Point

Addendum #1

- 1. If the bid exceeds \$100,000 prevailing wage rates must be utilized.
- 2. Base bids on re-using the existing base and provide a unit price in item #5 for removal and replacement of existing gravel base as necessary.
- 3. 3/4" recycled processed aggregate is not approved as base material.
- 4. Installation of wire mesh and dowels is limited to the 8" reinforced driveway sidewalk.
- 5. Integral sidewalk and curb is not anticipated for this project. Detail is provided in the event that it becomes necessary in a specific area. If necessary, a change order will be required.
- 6. Refer to detail for expansion joint filler.
- 7. The deadline for submission of bids will be extended to 10 a.m., Wednesday August 3, 2022, at the Department of Public Works, 6 Woolam Road, East Windsor, Connecticut.